



पावर ट्रांसमिशन कारपोरेशन ऑफ उत्तराखण्ड लि०  
(उत्तराखण्ड सरकार का उपक्रम)

14

अधीक्षण अभियन्ता (क्यू०ए०/क्यू०सी०) कार्यालय  
विद्युत भवन, नजदीक-आई०एस०बी०टी० क्रासिंग, सहारनपुर रोड, माजरा, देहरादून-248002  
दूरभाष एवं फैक्स नं० 0135-2643429, मो० 7088117921, email:- qaqc@ptcul.org

Letter No. /SE(QA/QC)/PTCUL

Date: /03/2018

M/s Bajaj Electricals Ltd.  
801, 8<sup>th</sup> Floor, Rustomjee Aspiree,  
Bhanu Shankar Yagnik Marg, Off,  
Eastern Express Highway Sion (E)  
Mumbai - 40022

Sent via e-mail

Subject:- Regarding vendor approval for Supply of steel Monopoles (up to 400 KV) in PTCUL.

Ref:- 1. Letter no. 655/मु०अभि०(परि० एवं अनु०)/पिटकुल/दिनांक 16.03.2018

Dear Sir,

Please refer your letter no. BEL/TLT/1212/01 dated 12.12.2017 for Vendor Registration in PTCUL. In this connection your works was inspected by Er. H. S .Hyanki SE (A) PTCUL, Haldwani on dated 02.02.2018 and your credentials were evaluated. It is to inform you that your vendor registration has been accepted by PTCUL & you are being registered as a vendor for supply of Steel Monopoles (upto 400 kv) in turnkey contracts and for participation in tenders for these items floated by PTCUL provided your company meets the PQR criteria of the respective floated tender. Your vendor registration has been accepted with following conditions:-

1. Company will have to follow the rules and regulation laid down by PTCUL.
2. The vendor registration will be applicable only if company qualifies the techno-commercial conditions of the respective tender.
3. Monopole supplied should be duly type tested as per relevant standards for it's design.
4. Drawing and GTP to be approved by Engineering Wing of PTCUL at the initial design stage of the Monopole as per respective contract.
5. Company has to get the approval of MQP before commencement of their production.
6. All required tests as per contract/relevant standard for Monopole to be carried out at the manufacturer place.
7. This acceptance does not absolve the company from contractual obligations & terms and conditions of the respective tender.
8. If any discrepancy observed in future the vendor registration may be cancelled without any prior notice for which M/s Bajaj Electricals Ltd., shall be fully responsible.

(Mant Ram)

Superintending Engineer (QA/QC)

Letter no. 211 /SE(QA/QC)/PTCUL

Copy forwarded to the following for kind information.

1. CE(O&M), PTCUL, Garhwal Zone, Roorkee
2. SE(O&M), PTCUL, Roorkee
3. SE(Engg.-Line), PTCUL, Vidyut Bhawan, Dehradun
4. DGM (IT), PTCUL, Vidyut Bhawan Majra Dehradun for uploading in PTCUL website.

Date 21/03/2018

(Mant Ram)

Superintending Engineer (QA/QC)