



# Power Transmission Corporation of Uttarakhand Ltd.

पावर ट्रांसमिशन कारपोरेशन ऑफ उत्तराखण्ड लि०

Vidyut Bhawan, Near ISBT Crossing,  
Sharanpur Road, Dehradun – 248002

Mob. 9837893749  
Telefax- 0135-2643429

E-mail: anil\_yadav@ptcul.org

No. /SE(QA/QC)/PTCUL

Dated: /11/2013

M/s Venson Electric Private Ltd.  
No. 331, 9<sup>th</sup> Cross, 4<sup>th</sup> Phase,  
Peenya Industrial Area,  
Bangalore – 560058,  
Ph.:- 080 – 28360223  
Fax- 080-28361335  
E-mail: info@vensonelectric.com

**Subject:- Regarding vendor approval for supply of C&R Panel by M/s Venson Electric Pvt. Ltd. in EPC Contract & Departmental Tenders PTCUL.**

Dear Sir,

Please refer your letter no. VEPL/NSS/APPROVAL-PTCUL dated 08.07.2013 for vendor registration in PTCUL. Your factory has been visited on dated 24.10.2013 by undersigned and was evaluated for Vendor Registrations for supply of C&R Panel in PTCUL through EPC Contracts & direct departmental tenders on evaluation of your credentials you are being registered as Vendor for supply of C&R Panel with Automation up to 220 KV projects through EPC Contracts & direct departmental tenders following terms & conditions:

- 1) Vendor should follow Manufacturing Quality Plan, rules & regulations along with Quality Assurance Plan of PTCUL.
- 2) All the main Relays of the Control Panels should be numerical relays/relays specified in particular tender manufactured by M/s ABB/Areva/Siemens/GE Make or any other make with due approval.
- 3) Relay used in the Control Panel should be from original manufacturer only but not from the traders.
- 4) This vendor registration does not absolve M/s Venson Electric Pvt. Ltd., New Delhi from your contractual liabilities of the respective tender.
- 5) Auxiliary relays shall be of M/s ABB/Areva/Siemens/GE /L&T Make or any other Make approved in PTCUL.
- 6) All the rules & regulations of PTCUL shall have to be followed.

(Anil Kumar)

Superintending Engineer (QA/QC)

Dated:- 28.11.2013

No. 1670 /SE(QA/QC)/PTCUL/

Copy forwarded to the following for kind information.

1. SE (Engg.), PTCUL Vidyut Bhawan, Majra, Dehradun.
2. DGM (IT), PTCUL, Vidyut Bhawan, Majra, Dehradun.  
(For uploading in website of PTCUL)

(Anil Kumar)

Superintending Engineer (QA/QC)